








Section - INLET TYPE 1




SECTION B-B




DETAIL OF ANCHOR
(SEE NOTES (5) & (7))



SECTION - INLET TYPE 2



PLAN



PROFILE

STEEL LIST

W	B	Gavanized Steel Angle	J Bar			
			Anchor	Size	Spacing	Length
1'-0"	3"	2 1/2"x2"x3/8"	2	#3	7"	1'-9"
1'-6"	"	"	"	"	"	2'-3"
2'-0"	"	"	"	"	"	2'-9"
2'-6"	"	"	"	"	"	3'-3"
3'-0"	"	"	3	"	"	3'-9"
3'-6"	"	"	"	"	6"	4'-3"
4'-0"	"	"	"	"	5"	4'-9"

NOTES

- FLOOR OF BOX TO BE TROWELED SMOOTH.
- WHEN THE TOE OF SLOPE IS WITHIN THE R/W, INLET TYPE 1 BEGINS AT THE TOE RATHER THAN AT THE R/W LINE.
- FOR OPEN DITCH APPROACH (TYPE 2) THE 2' EXTENSION IS NOT REQUIRED WHEN THE BACK OF WALK IS 2' OR MORE FROM THE R/W LINE.
- TOP OF INLET STRUCTURE (TYPE 1 & 2) TO BE FLUSH WITH ADJACENT SURFACE WHERE PRACTICABLE.
- A HEADED STEEL STUD 5/8"x 6 3/8" WITH HEAD D=1" ATTACHED BY A FULL PENETRATION BUTT WELD MAY BE USED AS AN ALTERNATE ANCHOR.
- NORMAL CURB FACE AT POINT M & Q, & PLUS 5" AT POINT N AND P.
- THE 3" LEG OF THE INTERIOR ANCHORS SHALL BE PARALLEL TO THE TOP OF SIDEWALK.
- FOR 'W' IN EXCESS OF 4'-0" A DOUBLE BOX STRUCTURE SHALL BE USED.



APPROVED BY:		24079 8/08/06	
JOHN P. SULLIVAN CITY ENGINEER		RCE DATE	
RECOMMENDED:		33340 8/07/06	
JIM MIMMACH		RCE DATE	
ASSISTANT CITY ENGINEER			
REV	DESCRIPTION	BY	APP'D DATE

CITY OF ONTARIO

PARKWAY DRAIN NO 1

STANDARD
DRAWING
NUMBER

3013